

Classification Report

Resistance to wind load
Watertightness
Air permeability



Test report 102 28261/2e*)

*) This test report is a translation of test report No. 102 28261/2 dated 08 February 2005. Only the German original is legally binding.


Client **ELVIAL S.A.**
Aluminium Extrusion
26th km national road

GR-61100 Thessaloniki-Kilkis
Greece

Basis

prEN 14351-1 : 2004-04,
Windows and external
pedestrian doorsets – Product
standard
Test standards:
EN 1026 : 2000-06
EN 1027 : 2000-06
EN 12211 : 2000-06

Representation



Product	Single tilt and turn door
Designation	5400 (without thermal break)
Exterior dimensions (W x H)	1204 mm x 2404 mm
Frame material	Aluminium
Special features	-/-

Instructions for use

The present test report serves to demonstrate the above characteristics for windows as set out by prEN 14351-1 :2004-04.

Validity

The data and results given relate solely to the tested and described test specimen.

The test results can be extrapolated to constructions of the same or smaller sizes of the same design, type of rebate and similar format under observation of the relevant casement weights.

The present test does not provide any information on the characteristics of the present design regarding performance and quality, in particular the effects of weathering and ageing were not taken into account.

Notes on publication.

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

Contents

The test report comprises a total of 7 pages.

- 1 Object
- 2 Procedure
- 3 Detailed results

Resistance to wind load – EN 12210



Class C5 / B5

Watertightness – EN 12208



Class 9A

Air permeability – EN 12207



Class 4

ift Rosenheim
25 April 2005

J. V. Jörn Peter Lass, Dipl.-Ing. (FH)
Commercial Director
ift Centre Windows and Facades

i. A. Markus Egli, Dipl.-Ing. (FH)
Test Engineer
ift Centre Windows and Facades



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing.(FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Straße 7-9
D-83026 Rosenheim
Tel.+49 (0) 8031 / 261-0
Fax+49 (0) 8031 / 261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 38 22
BLZ 711 500 00

Anerkannte Prüf-, Überwachungs-
und Zertifizierungsstelle
nach Landesbauordnung: BAY18
Notifizierung in Europa: Nr. 0757