

# Classification Report

Resistance to wind load  
Watertightness  
Air permeability



## Test report 102 28260/1e\*)

\*) This test report is a translation of test report No. 102 28260/1 dated 08 February 2005. Only the German original is legally binding.

Client **ELVIAL S.A.**  
**Aluminium Extrusion**  
**26th km national road**


**GR-61100 Thessaloniki-Kilkis**  
**Greece**

### Basis

prEN 14351-1 : 2004-04,  
Windows and external  
pedestrian doorsets – Product  
standard  
Test standards:  
EN 1026 : 2000-06  
EN 1027 : 2000-06  
EN 12211 : 2000-06

Product	Window unit with tilt and turn casement and fixed sublight
Designation	5600 (thermal break)
Exterior dimensions (W x H)	1407 mm x 2500 mm
Frame material	Aluminium thermal break profiles
Special features	-/-

### Representation



### Instructions for use

The present test report serves to demonstrate the above characteristics for windows as set out by prEN 14351-1 :2004-04.

### Validity

The data and results given relate solely to the tested and described test specimen.

The test results can be extrapolated to constructions of the same or smaller sizes of the same design, type of rebate and similar format under observation of the relevant casement weights.

The present test does not provide any information on the characteristics of the present design regarding performance and quality, in particular the effects of weathering and ageing were not taken into account.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

### Contents

The test report comprises a total of 8 pages.

- 1 Object
- 2 Procedure
- 3 Detailed results

### Resistance to wind load – EN 12210



**Class C3 / B3**

### Watertightness – EN 12208



**Class E 900**

### Air permeability – EN 12207



**Class 4**

ift Rosenheim  
25 April 2005

i. V. Jörn Peter Lass, Dipl.-Ing. (FH)  
Commercial Director  
ift Centre for Windows and Facades

i. A. Markus Egli, Dipl.-Ing. (FH)  
Test Engineer  
ift Centre for Windows and Facades



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Gietl-Straße 7-9  
D-83026 Rosenheim  
Tel.+49 (0) 8031 / 261-0  
Fax+49 (0) 8031 / 261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 38 22  
BLZ 711 500 00

Anerkannte Prüf-, Überwachungs-  
und Zertifizierungsstelle  
nach Landesbauordnung: BAY18  
Notifizierung in Europa: Nr. 0757